

# ELECTRICAL SAFETY INSPECTION TRACKER

Revision 1.2

Facility / Location: \_\_\_\_\_  
Inspector Name: \_\_\_\_\_  
Date of Inspection: \_\_\_\_\_  
Next Due Date: \_\_\_\_\_

INSPECTION ITEM / COMPONENT	PASS	FAIL	CORRECTIVE ACTION / OBSERVATIONS
Cords & Plugs: Condition / Ground Pins			<i>Check for fraying or exposed wires</i>
GFCI Outlets: Trip & Reset Function			<i>Test required in wet locations</i>
Panel Access: Clear 36" Clearance			<i>Ensure no obstructions</i>
Breakers: Proper Labeling / No Blanks			<i>Directory must be legible</i>
Surge Protectors: Not Daisy-Chained			<i>Direct wall connection only</i>
Conduits & J-Boxes: Secured / Closed			<i>No open knockouts or loose fittings</i>

INSPECTION ITEM / COMPONENT	PASS	FAIL	CORRECTIVE ACTION / OBSERVATIONS
Emergency Lighting / Exit Signs			<i>Battery backup test</i>
Grounding System: Visual Integrity			<i>Verify main ground bond</i>

**FINAL AUTHORIZATION**

Signature of Inspector  
Signature of Site Manager